

Spill Summary Report for NRC Report #1202865

Report Date: 9/14/2022

Report Time: 4:06 PM EDT

Region II Hotline Log Entry Information

Data ID: 2295373

Date Of Report: 1/25/2018

NRC #: 1202865

State #:

ERNS #:

Material Type: Oil

Receiver: Lucarino

Material / Amount:

DIELECTRIC FLUID (250 GALLON(S));

Location:

Street:

City: MANHATTAN

County: NEW YORK (MANHATTAN)

State: NY

Latitude:

Longitude:

Source of Pollution:

CONSOLIDATED EDISON COMPANY OF NEW YORK

Water Body:

NA

State Of EPA Responded:

No response Required

Initial EPA Action:

EPA Contacted RP

Status:

2 - Closed

URL:

Associated Action Reports

DataID: 1124638

Date: 1/26/2018	Time: 07:45	
Duty Officer/Responder Name: Lucarino	NRC Report #: 1202865	Hotline Log DataID: 2295373
Action Information		
Description: OSC Lucarino contacted Con Edison EH&S Control center, Con Ed located leak in a manhole in the Bronx, no discharge to waterway occurred. Con Ed clamped the leak, securing the discharge at approximately 0530 on 1/26/18. Approximately 450 gallons of dielectric fluid was discharged from the leak, however, the dielectric fluid was contained within the manhole structure. Con Ed is removing the oil.		
Follup-Up:		
Person Contacted		
Name: David Duke Organization: Con Edison Phone #: (212) 580-8383		

NRC Spill Report

NATIONAL RESPONSE CENTER 1-800-424-8802

GOVERNMENT USE ONLYGOVERNMENT USE ONLY***

Information released to a third party shall comply with any applicable federal and/or state Freedom of Information and Privacy Laws

Incident Report # 1202865

INCIDENT DESCRIPTION

*Report taken by: CIV ANTONAY GREER at 23:55 on 25-JAN-18

Incident Type: PIPELINE

Incident Cause: EQUIPMENT FAILURE

Affected Area:

Incident occurred on 25-JAN-18 at 23:37 local incident time.

Affected Medium: UNKNOWN

REPORTING PARTY

Name: DAVE DUKE

Organization: CONSOLIDATED EDISON COMPANY OF NEW YORK

Address: 31ST ST AND 20TH AVE

ASTORIA, NY 11105

PRIMARY Phone: (212) 5808383

Type of Organization: PUBLIC UTILITY

SUSPECTED RESPONSIBLE PARTY

Name: N/A

Organization: CONSOLIDATED EDISON COMPANY OF NEW YORK

Address: 31ST ST AND 20TH AVE

ASTORIA, NY 11105

PRIMARY Phone: (212) 5808383

Type of Organization: PUBLIC UTILITY

INCIDENT LOCATION

637 W. 49TH ST. County: NEW YORK (MANHATTAN)

City: MANHATTAN State: NY

* MAIN SUBSTATION LOCATION, EXACT LEAK SITE IS UNKNOWN.

RELEASED MATERIAL(S)

CHRIS Code: OMN Official Material Name: OIL, MISC: MINERAL
Also Known As: DIELECTRIC FLUID
Qty Released: 250 GALLON(S) Qty in Water: 0 UNKNOWN AMOUNT

DESCRIPTION OF INCIDENT

AN ESTIMATED 250 GALLONS OF NON-PCB DIELECTRIC FLUID IS DISCHARGING AT 33 GALLONS PER HOUR, AT A FLUID FILLED UNDERGROUND ELECTRIC TRANSMISSION FEEDER (M-51), FROM A 10" STEEL HIGH VOLTAGE TRANSMISSION PIPELINE. THIS WAS CAUSED BY SUSPECTED CORROSION; UNCONFIRMED. THE EXACT LOCATION OF THE RELEASE IS UNKNOWN, AS THE LINE RUNS FOR APPROX. 18 MILES BETWEEN TWO SUBSTATIONS.

INCIDENT DETAILS

Pipeline Type: TRANSMISSION
DOT Regulated: NO
Pipeline Above/Below Ground: BELOW
Exposed or Under Water: YES
Pipeline Covered: UNKNOWN

IMPACT

Fire Involved: NO Fire Extinguished: UNKNOWN
INJURIES: NO Hospitalized: Empl/Crew: Passenger:
FATALITIES: NO Empl/Crew: Passenger: Occupant:
EVACUATIONS: NO Who Evacuated: Radius/Area:

Damages: NO

		Hours	Direction of
<u>Closure Type</u>	<u>Description of Closure</u>	<u>Closed</u>	<u>Closure</u>
Air:	N		
Road:	N		Major Artery: N
Waterway:	N		
Track:	N		

Passengers Transferred: NO
Environmental Impact: UNKNOWN
Media Interest: UNKNOWN Community Impact due to Material:

REMEDIAL ACTIONS

- * CREWS ARE CURRENTLY CHECKING MANHOLES ASSOCIATED WITH THE PIPE.
- * A TECH VAN WITH AN OIL SENSOR IS CURRENTLY CHECKING THE AREA.
- * KEN'S MARINE WILL RESPOND TO HARLEM RIVER FIRST.

Release Secured: UNKNOWN
Release Rate: 33 GALLON(S) per HOUR
Estimated Release Duration:

WEATHER

Weather: CLEAR, 16 $\frac{1}{2}$ F

ADDITIONAL AGENCIES NOTIFIED

Federal:
State/Local:
State/Local On Scene:
State Agency Number:

NOTIFICATIONS BY NRC

CENTERS FOR DISEASE CONTROL (GRASP)
26-JAN-18 00:21 (770)4887100
DHS DEFENSE THREAT REDUCTION AGENCY (CHEMICAL AND BIOLOGICAL TECHNOLOGIES DEPARTMENT)
26-JAN-18 00:21 (703)7673477
DHS INFRSTR SECURITY COMPLIANCE DIV (REGION 2)
26-JAN-18 00:21 (202)4655909
DOT CRISIS MANAGEMENT CENTER (MAIN OFFICE)
26-JAN-18 00:21 (202)3661863
U.S. EPA II (MAIN OFFICE)
26-JAN-18 00:23 (732)3214370 OSC LUCARINO
NATIONAL INFRASTRUCTURE COORD CTR (MAIN OFFICE)
26-JAN-18 00:21 (202)2829201
NJ OFC HMLND SECURITY & PREPAREDNESS (COMMAND CENTER)
26-JAN-18 00:21 (609)9636817

NJ STATE POLICE (MARINE SERVICES BUREAU)
26-JAN-18 00:21 (609)9636900
NOAA RPTS FOR NY (MAIN OFFICE)
26-JAN-18 00:21 (206)5264911
NTSB PIPELINE (MAIN OFFICE)
26-JAN-18 00:21 (202)3146293
NY STATE DEC SPILL HOTLINE (MAIN OFFICE)
26-JAN-18 00:21 (518)4577362
PIPELINE & HAZMAT SAFETY ADMIN (OFFICE OF PIPELINE SAFETY (AUTO))
26-JAN-18 00:21 (202)3660568
SECTOR NEW YORK (COMMAND CENTER)
26-JAN-18 00:25 (718)3544356 PO COBB
USCG DISTRICT 1 (COMMAND CENTER)
26-JAN-18 00:21 (617)2238555

ADDITIONAL INFORMATION

*** END INCIDENT REPORT # 1202865 ***
Report any problems by calling 1-800-424-8802
PLEASE VISIT OUR WEB SITE AT <http://www.nrc.uscg.mil>